

University at Buffalo
FIRE CODE VIOLATION
Occupant Notification Form

Date Issued:	Corrections Due:	Violation Number:
Building:	Room #:	
Location:		Fine Class:
Department:	Dept. Head:	
Representative:	Phone #:	Rate:

Instructions: This document is given to the occupant where a New York State Fire Code violation exists. Please inform your supervisor of the violation(s) listed below so they may begin corrective action prior to the re-inspection by the New York State Fire Inspector.

- | Code # | Description |
|---------------|---|
| ___ F304.1 | - Combustible waste material accumulation in building or structure |
| ___ F315.2.1 | - Ceiling clearance not maintained (Sprinklered rooms 18"; Non-sprinklered rooms 24") |
| ___ F315.2.2 | - Combustible materials stored in exits or exit enclosures |
| ___ F315.2.3 | - Combustible material stored in boiler, mechanical, or electrical room |
| ___ F508.5.4 | - Access to fire department equipment obstructed |
| ___ F605.1 | - Appliance not plugged directly into outlet (non-portable) |
| ___ F605.3 | - Workspace clearance not maintained in front of electrical panel box 36" |
| ___ F605.4 | - Multi-plug adapter are non-compliant and shall be prohibited |
| ___ F605.5 | - Extension cords being used in place of permanent wiring |
| ___ F605.5.1 | - Daisy chaining of power strips |
| ___ F906.6 | - Fire extinguisher obstructed or obscured from view |
| ___ F1011.3 | - Means of egress is obstructed and not readily available for use |
| ___ F1011.4 | - Exit blocked by furnishings or decorations |
| ___ F1012.11 | - Required width of egress aisle not maintained |
| ___ F2703.5.1 | - Rooms or cabinets containing compressed gas not labeled |
| ___ F2704.4 | - Hazardous materials not properly stored- incompatible materials |
| ___ F3003.3.3 | - Compressed gas cylinders not properly secured |
| ___ F _____ | - Other _____ |

Explanation:

Questions regarding this document or for information on how the violation(s) should be abated may be directed to UB's Environment Health & Safety's Service Request Line at 829-2401.

Original: Occupant

Yellow Copy: EH&S

Pink Copy: Department